



Inlet - bottom of tank to invert of pipe - 31"
 Outlet - bottom of tank to invert of pipe - 29"

All dimensions inches.

Burial depth maximum 24" in a non-traffic area.

Tanks have large inlet baffles and effluent filter at outlet. Inspection spec. tag placed near inlet access. Accesses marked 'danger'. Joints have mastic seal. Ends marked IN/OUT. Two red pipe seal side inlets and black rubber boot type inlet and outlet connections. Inlet, outlet and centre accesses have standard concrete plug type manholes.

Recommended excavation size is 12" longer and 12" wider than tank dimensions. Depth should be over dug to allow 4" - 6" of sand for levelling/bedding purposes.

Babcock Supply Ltd. Precast Concrete
 1000 Gal/4500L Low Profile Septic Tank - Std. Construction