



**NOTES:**

- 1 Outlet hole size 525mm diameter maximum, location as required.
- 2 200mm diameter knockout shall accommodate subdrain. Knockout shall be 60mm deep.
- A Centre reinforcing in base slab and walls  $\pm 20$ mm.
- B Granular backfill shall be placed to a minimum thickness of 300mm all around the catch basin.
- C Frame, grate, and adjustment units shall be installed according to OPSD 704.010.
- D Pipe support shall be according to OPSD 708.020.
- E All dimensions are nominal.
- F All dimensions are in millimetres unless otherwise shown.

ALTERNATE STANDARD HEIGHTS	
ALTERNATE	DIMENSION
A	1980
B	1830

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2009 Rev 2

**PRECAST CONCRETE  
TWIN INLET CATCH BASIN**  
600 x 1450mm



**OPSD 705.020**